

## SUMMARY SHEET for PERMIT APPLICATION

(This Summary Agenda Sheet to be used for ALL permits in this category for which Board approval is recommended.)

DATE: February 7, 2018

PORT PERMIT NO: 5172

BUILDING PERMIT APPLICATION:      New Construction      Addition   X   Alteration  
     Demolition      Repair      Other, Tank

PORT TENANT:

FedEx

PERMIT APPLICANT:

FedEx

LOCATION OF PROPOSED WORK: 1 Sally Ride Way

BRIEF DESCRIPTION OF PROPOSED WORK: Modifications to aircraft power supply that provides 400Hz power to each parking gate. The existing system has a centralized 60Hz to 400Hz converter that must remain energized at all times serving 400Hz power to each gate. The new system will run the 60Hz power to the gates and convert to 400Hz at each gate as needed with portable converters. This system will use less power and be more reliable so that use of back-up fuel powered generators will be less necessary. The work includes replacement of electrical equipment to remove the centralized converter and provide 60Hz power to each gate that will be converted to be 400Hz for planes as needed. The improvement does not change or expand the existing use has been determined to be Categorically Exempt from CEQA per Section 15301, Class 1(c), alteration of existing electrical conveyance.


SCHEDULED FOR

BOARD ACTION: Date: February 22, 2018

VALUATION OF

WORK: \$ 250,000

FROM: PORT PERMITS, ENVIRONMENTAL PROGRAMS & PLANNING

  
Recommend Approval

Date: 2/7/18

ROUTE TO: (Please sign and send to next on list ASAP)

(1) PORT ENVIRONMENTAL ASSESSMENT SUPERVISOR, ENVIRONMENTAL PROGRAMS & PLANNING


ASSESSMENT: Categorically Exempt, Section 15301, Class 1(a)

Cat. Ex., Neg. Dec., Mit. Neg. Dec., or EIR

  
Recommend Approval


Date: 02/07/18

(2) DIRECTOR OF ENGINEERING

  
Recommend Approval


Date: 2/8/18

(3) EXECUTIVE DIRECTOR

  
Recommend Approval

Date: 2-8-18

(4) PORT PERMITS - ENGINEERING SERVICES DEPARTMENT:

  
Received By:

Date: 2/8/18

BOARD APPROVAL: Resolution No: \_\_\_\_\_ Date: \_\_\_\_\_